

CR-100 AND CR-200 SYNTHETIC ZEOLITES

Listing Under NSF/ANSI Standard No. 61



Tested and Certified by WQA
against NSF/ANSI 61 for
material safety only.

NSF/ANSI-61 International Standard for Drinking Water Additives

NSF/ANSI-61 Drinking Water System Components - Health Effects

This Standard establishes minimum health effects requirements for the chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems. This Standard does not establish performance, taste and odor, or microbial growth support requirements for drinking water systems products, components, or materials.

Drinking Water Treatment Products certified to NSF/ANSI 61 have not been tested or evaluated for contaminant reduction performance. Contaminant reduction testing and certification claims shall be evaluated via the industry's residential drinking water treatment standards.